

S P E C I F I C A T I O N S

- A.** This specification defines the requirements for a Wager 2050-1350 Vent Scrubber 2050FAPC-1350 manufactured by Wager Company in Rural Hall, NC. ISO 9001 : 2015 REGISTERED COMPANY Cert No. US4050
- B.** The 2050FAPC-1350 consists of dry-scrubbing media contained in a fabricated 5052 alum or 316SS plate housing, with a 6"-12" inlet.
- C.** The 2050FAPC-1350 shall contain 41³ cf of dry-scrubbing media that is engineered for the removal of H₂S gas. The media is contained in 27 corrugated plastic container that is 11" x 18" in size.
- D.** The airflow shall be designed for passive applications. The configuration shall be arranged so that the contaminated air shall flow from the bottom flange and be forced upward through the media bed and discharged through ventilated openings.
- E.** The 2050FAPC-1350 contains 16 air admittance valves, Intake air directly into the lines without any restrictions from the unit's media bed. This assures continued airflow during pumping sequences needed with air release valves, and also with a vacuum sewer system where outside fresh air is required for system operation.
- F.** All components of the 2050FAPC-1350 shall include:
- 1 A fabricated 5052 Alum or 316 Stainless steel plate body
 - 2 41³ cf. of odor controlling media engineered in pellet form
 - 3 6"- 12" flanged connection – Optional metric flange
 - 4 Tamper proof lockable hook and security latches
 - 5 Disposable media corrugated plastic insert
- G.** Vent Scrubber Material
1. Fabricated Aluminum plate or 316ss
 2. Twenty seven corrugated plastic canisters measuring 11 6" x 18" each containing 1.5³ cf. of media.
 3. Latches in 316SS
 4. Hooks in 316SS
 5. 41³ cf. of odor controlling media designed for removal of H₂S gas
 6. 6" - 12" Flanged Connection
 7. Plastic Drum vent scrubbers that contain activated alumina media or carbon will not be accepted.
 8. Media must be Non-Hazardous before and after it is spent.
- H.** Media Specification
1. Moisture Content: 35% Max
 2. Crush Strength: 35%-70% Max
 3. Abrasion: 4.5% Max
 4. Pellet Diameter: 1/16" – .1" (1.5mm-6.5mm)
- I.** Wager media only will be accepted due to the high level of capacity. No equals will be accepted. Carbon will not be accepted.
- J.** Only UL certified media will be accepted in Wager's vent scrubber.
- K.** Registered ISO 9001 company only
- L.** The general contractor is responsible for all design cost changes, engineer review time, and testing verification.
- M.** Analytical Services:
1. Samples of the media may be analyzed in order to predict the life of the system media at Wager's expense.
- N.** Built in Water Separator / mist eliminator
1. The body of the water separator is constructed from 5052 aluminum plate and is epoxy coated for protection from harsh environments, or the option of 316ss
 2. The overall measurements of the unit are 10ft x 4ft x 4ft high
 3. 6-12" flanged threaded aluminum connection provided for attaching to the 2050-1350
 4. Valve Assembly with float allows for excess accumulated water to be expelled.
 5. An inlet stem provides an exit for accumulated moisture from the air release valve.
 6. A perforated plate provides drainage of excess water from the mist eliminator pad.
 7. A Nitrile gasket allows for a tight fit of the aluminum plate cover.
 8. SS ¼-20 pem nuts seal the top plate
- O.** Mist Eliminator Mesh Pads
1. Designed to remove 99% of water vapor.
 2. (4) 24" x 24" mist Eliminator pads
 3. MESH: PP, T max = 210° F
 4. 2.2 inches, nominal thickness TOP & BTM GRIDS